



NOTES:

1. DETAIL DESIGNED FOR JOINTS WITH MAX. MOVEMENT ACCOMMODATION FACTOR OF 25%.
2. TREATED WOOD BLOCKING, CONCRETE MASONRY UNITS, ETC., CAN BE SUBSTITUTED FOR P.I.P. CONCRETE CURB.
3. DIAMETER OF FOAM ROD OR TUBE SHOULD BE 1" LARGER THAN MAXIMUM AS-BUILT JOINT OPENING.
4. SPLICE TAPE SHOULD BE USED AT EXPOSED LAPS OF CONSECUTIVE PIECES OF FLEX-FLASH UN



Monolithic
Membrane
6125-FR
ROOFING SYSTEMS

AMERICAN HYDROTECH, INC.

FIELD EXPANSION JOINTS
1" - 2" MAX. AS-BUILT WIDTHS

SCALE: NONE
DATE: 02/04/19

R-6B