



**NOTES:**

1. DETAIL DESIGNED FOR JOINTS WITH MAX. MOVEMENT ACCOMMODATION FACTOR OF 25%.
2. IF CURBING THE DETAIL IS NOT FEASIBLE, APPROPRIATE PROTECTION IS REQUIRED TO DIVERT WATER AWAY AND PREVENT MECHANICAL DAMAGE.
3. TREATED WOOD BLOCKING, CONCRETE MASONRY UNITS, ETC., CAN BE SUBSTITUTED FOR P.I.P. CONCRETE CURB.
4. DIAMETER OF FOAM ROD OR TUBE SHOULD BE 1" LARGER THAN MAXIMUM AS-BUILT JOINT OPENING.
5. SPLICE TAPE SHOULD BE USED AT EXPOSED LAPS OF CONSECUTIVE PIECES OF FLEX-FLASH UN

	<p><b>Monolithic Membrane 6125-FR</b> ROOFING SYSTEMS</p>
<p><b>AMERICAN HYDROTECH, INC.</b></p>	

<p><b>DECK-TO-WALL EXPANSION JOINT 1" - 2" MAX AS BUILT WIDTHS</b></p>	
<p>SCALE: NONE DATE: 02/04/19</p>	<p>R-6D</p>