


- NOTES:
1. PENETRATION MUST BE PROPERLY SECURED TO STRUCTURE TO PREVENT VERTICAL OR LATERAL MOVEMENT. EXPOSED DECK CLAMPS ARE NOT APPROPRIATE.
 2. ALL PIPE MATERIALS (PVC, COPPER, BRASS) REQUIRE ROUGHENING/SANDING, IN ADDITION TO WIPING W/SURFACE CONDITIONER FOR PROPER ADHESION OF MM6125. METAL PIPES MUST BE FREE OF ALL OIL AND RUST.
 3. IN COVERED/BURIED CONDITIONS, THE FLASHING DETAIL SHOULD EXTENDED AS HIGH AS POSSIBLE. FLASHING MUST BE TERMINATED AT OVERBURDEN LEVEL AND NO LESS THAN 8" ABOVE SUBSTRATE.



Monolithic Membrane 6125-FR
ROOFING SYSTEMS

AMERICAN HYDROTECH, INC.

TYP. ROUND PENETRATIONS (PIPE, VENT, ETC.)

SCALE: NONE DATE: 12/01/17	R-7B
-------------------------------	------

This information is intended only for general conceptual purposes. It is based on data and knowledge considered to be true and correct. It is offered for the user's consideration, investigation and verification and is not intended to substitute for the advice provided by appropriate professionals. Hydrotech assumes no liability for the use of this information. The determination of the suitability and applicability of this information is the sole responsibility of the user.