



NOTES:

1. IN COVERED/BURIED CONDITIONS, MM6125 IS EXTENDED AS CONTINUOUS FLASHING AS HIGH AS POSSIBLE. FLASHING MUST BE TERMINATED AT OVERBURDEN LEVEL AND NO LESS THAN 4" ABOVE SUBSTRATE.
2. REGLETS CAN BE CAST/FORMED OR CUT INTO THE CONCRETE. REGLETS SHOULD BE MIN. 1/2" DEEP AND PROVIDE AN EASY TRANSITION FOR THE MEMBRANE FLASHING.
3. ADDITIONAL REINFORCEMENT NOT REQUIRED AT TYPICAL CONSTRUCTION/CONTROL JOINTS WITH THE FR (FABRIC REINFORCED) MEMBRANE ASSEMBLY.

**Hydrotech**

**Monolithic Membrane 6125-FR**  
WATERPROOFING SYSTEMS

**AMERICAN HYDROTECH, INC.**

**CONCRETE CONSTRUCTION JOINTS**

SCALE: NONE DATE: 11/01/17	W-4
-------------------------------	-----

This information is intended only for general conceptual purposes. It is based on data and knowledge considered to be true and correct. It is offered for the user's consideration, investigation and verification and is not intended to substitute for the advice provided by appropriate professionals. Hydrotech assumes no liability for the use of this information. The determination of the suitability and applicability of this information is the sole responsibility of the user.