


**NOTES:**

1. DETAIL DESIGNED FOR JOINTS WITH MAX. MOVEMENT ACCOMMODATION FACTOR OF 25%.
2. BACKER ROD AND SEALANT ARE REQUIRED IN JOINT PRIOR TO MM6125/FLEX-FLASH UN INSTALLATION.
3. IN COVERED/BURIED CONDITIONS, MM6125 IS EXTENDED AS CONTINUOUS FLASHING AS HIGH AS THE OVERBURDEN LEVEL. FLASHING MUST BE TERMINATED NO LESS THAN 4" ABOVE SUBSTRATE. IN ADDITION, ADEQUATE PROTECTION MUST BE PROVIDED FOR FLASHING FROM SUBSEQUENT TOPPING/ BACKFILL. (SEE W-6B) WHENEVER POSSIBLE THE EXPANSION JOINT SHOULD BE EXTENDED UP THROUGH ALL TOPPING LAYERS.
4. REGLETS CAN BE CAST/FORMED OR CUT INTO THE CONCRETE. REGLETS SHOULD BE MIN. 1/2" DEEP AND PROVIDE AN EASY TRANSITION FOR THE MEMBRANE FLASHING.

	<p><b>Monolithic Membrane 6125-FR</b> WATERPROOFING SYSTEMS</p>
<p><b>AMERICAN HYDROTECH, INC.</b></p>	

<p><b>EXPANSION JOINTS UP TO 1" AS-BUILT WIDTH</b></p>	
<p>SCALE: NONE DATE: 11/01/17</p>	<p>W-6A</p>

This information is intended only for general conceptual purposes. It is based on data and knowledge considered to be true and correct. It is offered for the user's consideration, investigation and verification and is not intended to substitute for the advice provided by appropriate professionals. Hydrotech assumes no liability for the use of this information. The determination of the suitability and applicability of this information is the sole responsibility of the user.