

- 1. PENETRATION MUST BE PROPERLY SECURED TO STRUCTURE TO PREVENT VERTICAL OR LATERAL MOVEMENT. EXPOSED DECK CLAMPS ARE NOT APPROPRIATE.
- 2. SOME PIPE MATERIALS (PVC, COPPER, BRASS) MAY REQUIRE ROUGHENING/SANDING, IN ADDITION TO WIPING W/SURFACE CONDITIONER FOR PROPER ADHESION OF MM6125. METAL PIPES MUST BE FREE OF ALL OIL AND RUST.
- 3. THE SAME DETAILING ABOVE WOULD BE EMPLOYED FOR PENETRATIONS THROUGH VERTICAL/FOUNDATION WALL APPLICATIONS.
- 4. IN COVERED/BURIED CONDITIONS, THE FLASHING DETAIL SHOULD EXTENDED AS HIGH AS POSSIBLE. FLASHING MUST BE TERMINATED AT OVERBURDEN LEVEL AND NO LESS THAN 6" ABOVE SUBSTRATE.



TYP. ROUND PENETRATIONS (PIPE, CONDUIT, ETC.)

SCALE: NONE DATE: 11/01/17

W-7A