


IRREGULAR SHAPED PENETRATIONS REQUIRING THE USE OF SIKALASTIC RAPID RESIN CAN INCLUDE COLUMNS, ANGLES, DAVITS, SQUARE TUBE STEEL, ETC. LIGHTER GAUGE DUCT/PIPING SUPPORTS ARE NOT APPROPRIATE AND SHOULD BE PLACED ON BALLAST BLOCKS.



NOTES:

1. WHEN POSSIBLE, MM6125 SHOULD BE APPLIED UNDER PENETRATION BASE PLATE.
2. PENETRATION SURFACE MUST BE CLEAN AND FREE OF ALL RUST AND OTHER CONTAMINANTS, IN ADDITION TO WIPING W/SURFACE CONDITIONER FOR PROPER ADHESION OF MM6125.
3. IN COVERED/BURIED CONDITIONS, THE FLASHING MEMBRANE SHOULD EXTENDED AS HIGH AS POSSIBLE.
4. FLASHING MUST BE TERMINATED AT OR ABOVE OVERBURDEN LEVEL AND NO LESS THAN 8" ABOVE SUBSTRATE.
5. USE LARGEST SHEETS OF FLEX FLASH UN AS POSSIBLE.
6. A HOLE/SLIT SMALLER THAN THE PENETRATION SHOULD BE CUT IN THE CENTER OF THE FLEX FLASH UN AND THE SHEET PULLED DOWN OVER THE PENETRATION PROVIDING A "SNUG" FIT.
7. CUT A SLIT OR "X" INTO THE FLEX FLASH UN DIRECTLY OVER THE BOLT HEADS TO ALLOW EMBEDDING INTO THE MM6125, FORMING TIGHTLY AROUND BOLT HEAD.
8. SIKALASTIC RAPID 724 RESIN SHOULD BE APPLIED DIRECTLY OVER PRIMED SUBSTRATES (SEE APPLICATION GUIDE FOR APPROPRIATE SIKALASTIC RAPID PRIMER SELECTION)

BUILDING TRUST
312-337-4998



IRREGULAR SHAPE PENETRATION WITH BASE PLATE

SCALE:

N.T.S.

DATE:

12-2025

FILE NO.:

MM6125

DRW. NO.:

R-10B

AS A MEMBRANE MANUFACTURER, SIKA CORPORATION ("SIKA") REVIEWS DETAILS PREPARED BY THE CONSULTANT, ARCHITECT AND/OR ENGINEER FOR A PROJECT SOLELY FOR THE PURPOSE OF DETERMINING IF A SIKA WARRANTY MAY ISSUE FOR THE PROJECT. THIS REVIEW IS NOT TO BE CONSTRUED AS APPROVAL OF DETAILS BY SIKA AND IS NOT BEING CONDUCTED IN LIEU OF SOUND ENGINEERING AND ARCHITECTURAL PRACTICES AND JUDGMENT AND SHOULD NOT BE RELIED UPON FOR THAT PURPOSE. SIKA CORPORATION ASSUMES NO LIABILITY WITH RESPECT TO THE DESIGN OF THE ROOFING OR WATERPROOFING SYSTEM. THE ARCHITECT, CONSULTANT AND/OR ENGINEER OR DESIGN PROFESSIONAL FOR A PARTICULAR PROJECT BEARS THE SOLE RESPONSIBILITY FOR THE DESIGN OF THE ROOFING OR WATERPROOFING SYSTEM, FOR THE PREPARATION AND APPROVAL OF THE DETAILS AND SHOP DRAWINGS, AND FOR DETERMINING THEIR SUITABILITY FOR A PARTICULAR PROJECT OR APPLICATION. WHILE SIKA PROVIDES GENERAL INSTRUCTIONS FOR THE INSTALLATION OF ITS MEMBRANE AS WELL AS TRAINING FOR SIKA AUTHORIZED APPLICATORS, THE MEANS AND METHODS USED BY THE CONTRACTOR FOR SURFACE PREPARATION AS WELL AS THE MEANS AND METHODS EMPLOYED BY THE CONTRACTOR IN THE INSTALLATION OF THE SIKA MEMBRANE ARE THE RESPONSIBILITY OF THE CONTRACTOR. ALL SALE OF SIKA PRODUCTS AND SERVICES ARE SUBJECT TO SIKA'S TERMS AND CONDITIONS OF SALE AVAILABLE AT HYDROTECHUSA.COM.